



Engineering & Public Works
416 West Broadway Ave. Maryville, TN 37801
(865) 273-3500 | www.maryvillegov.com

Addendum #1

Bid No. 04-24

College Street Roadway Improvements

Addendum Date: March 14, 2024

Opening Date: March 19, 2024
plans

Owner: City of Maryville

Total Pages: 7 pages PLUS revised

The following addendum was issued during the bidding process for the project and is included herein as part of the construction documents (Total addenda issued: 1 of 1).

Description of Addendum #1:

Answers to questions about the project bid, a revised bid schedule, and a revised plan set based on the response to questions 1 and 6 :

1. There is no bid item for the TrafficScapes decorative crosswalks. Will a bid item added for this? If not, which item should we include this work in?

A new bid form will be issued with addendum 1 which will have a line item for Decorative Crosswalk (SF).

2. Will any of the road be able to be closed during this project? If the road could be closed in sections, that would significantly cut down on project time and cost if so. On that note, the traffic control sheets reference a traffic control plan, but there is nothing other than sheets T-1 and T-2 which does not provide a traffic control or phasing plan. Is the phasing/traffic control plan up to the contractor?

No traffic control plan will be provided. It will be up to the contractor to develop a traffic control plan in accordance with the MUTCD. Various sections of the roadway may be closed at times, so long as access to properties are maintained.

3. There are multiple locations that the contractor will be removing asphalt (i.e. new curb islands in farmer's market parking lot, multiple locations on College Street for curbs, concrete plaza

area up to start of brick sidewalk off High Street on Melissa Connor's property, etc.). Can a removal of asphalt item be added to the contract to cover this cost? If not, which item should we include this work in?

All pavement removal, concrete removal, obstructions or other items demolished may be included in the item #3 Removal of Structures and Obstructions. No additional item will be added.

4. There are multiple locations that the contractor will be removing existing sidewalks. Can a removal of sidewalks item be added to the contract to cover this cost? If not, which item should we include this work in?

All pavement removal, concrete removal, obstructions or other items demolished may be included in the item #3 Removal of Structures and Obstructions. No additional item will be added.

5. Does "Item 7 – Mineral Aggregate, Type A Base, Grading D" include the base stone under the sidewalks, driveways, curbs, etc.? If not, will it be added or should we include that in each respective concrete item?

This item includes the base stone for sidewalks, driveways, etc.

6. It looks like the intent is to remove the sidewalk up against a concrete wall between the Ruby Tuesday building's back corner and their parking lot entrance on the right side of College going away from E Church Street. Has there been any inspection of this wall? It will be extremely difficult to remove that sidewalk without damaging the wall especially since the wall looks to be in rough shape.

This section of sidewalk will be removed from the project until a suitable repair to the wall can be made.

7. Is the 3 piece limestone cap to be included in price for the "Brick Column" item?

Yes, include any items associated with the columns in the brick column item.

8. Is the intent to leave the bridge between Church and Ellis untouched in this contract?

Yes, the bridge pavement and sidewalk will remain untouched through this project.

9. Does the contractor need to provide concrete testing?

No concrete testing will be required.

10. To what depth will the existing brick crosswalks need to be excavated?

The existing concrete work (including stamped concrete and concrete curbs) will need to be completely removed and replaced with full depth asphalt pavement to prepare for the installation of the decorative crosswalk material.

11. What is “Item 55 - Soil and Amendments” to be used for?

This item is for the landscaped areas to ensure that quality topsoil is used for plantings.

- **Replace original plan set with Revised Plan Set for Addendum 1.**
- **Replace original Bid Form with Revised Bid Schedule for Addendum 1.**

End of Addendum No. 1

Appendix A

Addendum 1 Revised Bid Schedule

Bid 04-24 College St Streetscape - Construction Plans Addendum #1

BID #04-24 ADDENDUM 1 REVISED

Bid Schedule

ITEM NO.	TDOT ITEM NO.	DESCRIPTION	UNIT	QTY.	UNIT PRICE	TOTAL COST
1	105-01	CONSTRUCTION STAKES, LINES AND GRADES	LS	1		
2	201-01	CLEARING AND GRUBBING	LS	1		
3	202-01	REMOVAL OF STRUCTURES AND OBSTRUCTIONS	LS	1		
4	203-01	ROAD & DRAINAGE EXCAVATION (UNCLASSIFIED)	CY	230		
5	203-06	WATER	MG	6		
6	209-99.91	EROSION CONTROL	LS	1		
7	303-01	MINERAL AGGREGATE, TYPE A BASE, GRADING D	TON	650		
8	307-01.06	ASPHALT CONCRETE MIX (PG64-22) (BPMB-HM) GRADING B	TON	38		
9	307-02.08	ASPHALT CONCRETE MIX (PG70-22) (BPMB-HM) GRADING B-M2	TON	85		
10	403-01	BITUMINOUS MATERIAL FOR TACK COAT (TC)	TON	1.5		
11	407-20.05	SAW CUTTING ASPHALT PAVEMENT	LF	1975		
12	411-01.10	ACS MIX(PG64-22) GRADING D	TON	275		
13	415-01.01	COLD PLANING BITUMINOUS PAVEMENT	TON	231		
14	604-20.11	PAINTED METAL HANDRAIL	LF	345		
15	607-01.02	12" CONCRETE PIPE CULVERT (CLASS III)	LF	100		
16	611-01.02	MANHOLES, > 4' - 8' DEPTH	EACH	1		
17	611-12.01	CATCH BASINS, TYPE 12, 0' - 4' DEPTH	EACH	2		
18	611-42.01	CATCH BASINS, TYPE 42, 0' - 4' DEPTH	EACH	1		
19	611-42.02	CATCH BASINS, TYPE 42, 4' - 8' DEPTH	EACH	2		
20	701-01.01	CONCRETE SIDEWALK (4 ")	SF	12610		
21	701-01.20	BRICK SIDEWALK	SY	550		
22	701-02	CONCRETE DRIVEWAY	SF	1925		

23	701-02.03	CONCRETE CURB RAMP	SF	1915		
24	702-01	CONCRETE CURB	CY	70		
25	702-03	CONCRETE COMBINED CURB & GUTTER	CY	20		
26	712-01	TRAFFIC CONTROL	LS	1		
27	713-02.21	SIGN POST DELINEATION ENHANCEMENT	LF	68		
28	713-11.02	PERFORATED/KNOCKOUT SQUARE TUBE POST	LB	480		
29	713-13.02	FLAT SHEET ALUMINUM SIGNS (0.080" THICK)	SF	42		
30	713-13.03	FLAT SHEET ALUMINUM SIGNS (0.100" THICK)	SF	99		
31	713-15	REMOVAL OF SIGNS, POSTS AND FOOTINGS	LS	1		
32	716-02.05	PLASTIC PAVEMENT MARKING (STOP LINE)	LF	65		
33	716-02.09	PLASTIC PAVEMENT MARKING (LONGITUDINAL CROSS-WALK)	LF	120		
34	716-02.12	PLASTIC PAVEMENT MARKING (8IN LINE)	LM	0.8		
35	716-03.08	PLASTIC WORD PAVEMENT MARKING (PED-XING)	EACH	2		
36	716-05.01	PAINTED PAVEMENT MARKING (4" LINE)	LM	1.8		
37	716-08.01	REMOVAL OF PAVEMENT MARKING (LINE)	LF	2640		
38	716-12.02	ENHANCED FLATLINE THERMO PVMT MRKNG (6IN LINE)	LM	0.3		
39	717-01	MOBILIZATION	LS	1		
40	801-03	WATER (SEEDING & SODDING)	MG	3		
41	802-01.10	TREE (SKYLINE HONEY LOCUST)	EACH	12		
42	802-01.11	TREE (AUTUMN BRILLIANCE SERVICEBERRY)	EACH	8		
43	802-01.12	TREE (GREENSPIRE LITTLELEAD LINDEN)	EACH	5		
44	802-01.13	TREE (CUPRESSINA NORWAY SPRUCE)	EACH	1		
45	802-03.01	SHRUB (RED SPRITE WINTERBERRY)	EACH	64		
46	802-03.02	SHRUB (VIRGINIA SWEETSPIRE)	EACH	18		

47	802-03.03	SHRUB (OAKLEAF HYDRANGEA)	EACH	61		
48	802-03.04	SHRUB (AUTUMN FERN)	EACH	126		
49	802-03.05	SHRUB (LITTLE LIME HYDRANGEA)	EACH	9		
50	803-01	SODDING (NEW SOD)	SY	220		
51		GROUND COVER (DENSIFLORA LILYTURF)	EACH	1490		
52		GRASS (FEATHER REED GRASS)	EACH	30		
53		GRASS (LITTLE BLUESTEM GRASS)	EACH	41		
54		TREEGATOR BAG	EACH	18		
55		SOIL AND AMENDMENTS	LS	1		
56		MULCH	LS	1		
57		BRICK COLUMNS FOR "CITY OF MARYVILLE" SIGN	EACH	4		
58		DECORATIVE CROSSWALK	SF	2360		
		Bid Schedule Total				
(written in words)						

END OF BID SCHEDULE